LISTING SERVICE

LISTING No. 7165-0900:131

CATEGORY: Control Unit (Non High-Rise)

LISTEE: Fike Protection Systems, 704 S. 10th St., Blue Springs MO 64015
Contact: Kevin Montgomery (816) 229-3405 FAX (816) 229-5082

DESIGN: Models GP-10UD fire alarm control unit. Power-limited; non-coded, local, remote station and central station service; manual, automatic, waterflow and sprinkler supervisory service. Refer to listee's data sheet for additional detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical ratings, and UL Label.

APPROVAL: Listed as a fire alarm control unit for use with separately listed electrically compatible initiating and indicating devices. Refer to manufacturer's Installation Manual for details.

This control unit can generate a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1999 Edition.

NOTE: For ***Fire Alarm Verification Feature*** (delay of fire alarm signal), the maximum Retard/Reset/Restart period shall not exceed 30 seconds.

XLF: 7165-0075:177

01-23-04

Date Issued: **JUNE 21, 2004** *Listing Expires June 30, 2005*

Authorized By: ***DIANE K. AREND***, *Senior Deputy*
Program Manager